


SCHOOL SANITARY CERTIFICATE

I hereby declare that I have inspected the school "ANANDSAGAR PUBLIC SCHOOL, CHINCHANI- TASGAON" building and premises on the day of and certify.

That the accommodation provided for each of the several classes is sufficient for the minimum number of pupils taught therein and is properly ventilated and lighted:


- That the building is maintained in substantial repair
- That is neat and Clean:
- That the latrine arrangement are adequate and satisfactory:
- That the supply of drinking water is wholesome: and that in all other necessary respects the sanitation is good.

Counter signed

Signature 
MEDICAL OFFICER
A.H.C. CHINCHANI

Designation **19 OCT 2022**




Principal
Anandsagar Public School
Tasgaon, Dist. Sangli. 416312

JOGLEKAR ANALYTICAL LABORATORY

810, Joglekar Wada, Tasgaon, Dist. Sangli – 416 312

Tel: +91 9422041486 Email: vvjog@yahoo.com

Name : Shri Rajendra Annasaheb Patil
Address : A/P Tasgaon
Date of Sample : Apr. 7, 2022
Water Source : Bore Well
Sample No. : W-11/22-23
Plot No. : --

Water Analysis

| Parameters | Unit | Analysis Value | Standard |
|--|------------|----------------|------------|
| pH (पीएच) | -- | 7.42 | 5.5 – 7.75 |
| EC (विद्युत वाहकता) | mmhos/cm | 0.068 | < 1.00 |
| Carbonates (कार्बोनेट्स) | mg/lit | Nil | < 50 |
| Bicarbonates (बायकार्बोनेट्स) | mg/lit | 25 | < 610 |
| Hardness as CaCO ₃ (हार्डनेस) | mg/lit | 20 | < 500 |
| Sodium (सोडियम) | mg/lit | 9.11 | < 100 |
| Calcium (Ca) (कॅल्शियम) | mg/lit | 6.22 | < 80 |
| Chlorides (क्लोराईड) | mg/lit | 21.30 | < 160 |
| MPN (Bacterial count) | MPN /100ml | Nil | Nil |
| TDS (Total Dissolved Solids) | Mg/lit | 31 | < 500 |


Note:

All the above parameters are within the standard range. Water quality is suitable for drinking purpose.

Analysed by

Vivek Joglekar
Date: April 18, 2022




Principal
Anandsagar Public School
Tasgaon, Dist. Sangli. 416 312

(तपासणी नमुना घेण्याची प्रक्रिया प्रयोगशाळेच्या नियंत्रणाबाहेर असल्याने तपासणी अहवालाची अचूकता दिलेल्या नमुन्यापुरतीच मर्यादित राहिल. इतर कोणतीही जबाबदारी प्रयोगशाळा स्वीकारणार नाही)